

PLEASE NOTE: Legislative Information **cannot** perform research, provide legal advice, or interpret Maine law. For legal assistance, please contact a qualified attorney.

Amend the bill in section 1 in subsection 1-A in the 6th line (page 1, line 9 in L.D.) by inserting after the following: "fuels" the following: 'as long as a carbon monoxide detector is installed in the building near a bedroom'

Amend the bill in section 2 in §2402-A in the first paragraph in the 4th line (page 1, line 17 in L.D.) by inserting after the following: "fuels" the following: 'as long as a carbon monoxide detector is installed in the building near a bedroom'

## SUMMARY

This amendment, which is the majority report of the committee, allows the use of a single chimney flue to vent 2 appliances that use different fuels as long as a carbon monoxide detector is installed in the building near a bedroom.